

Product Overview (for complete specifications, see pages 2 & 3) ****** See last page for APPROVED CUT RELEASE.

Quick Ship: Most product options are shippable within 2-3 weeks! Check our Quick Ship Guide for details.

Construction: BABA, ARRA, RoHS, REACH and Prop 65 compliant. Extruded aluminum housing for superior fit and finish. Runs and patterns can be built to field dims., including fully illuminated corners.

Unbroken Illumination: Continuous illumination in custom-length runs and patterns with illuminated corners.

Electrical: LED components by major manufacturers, may be upgraded in the field to increase energy efficiency. Fixtures can be fitted with specialty LED and control components (consult factory). Standard Output, High Output and Custom Output options available.

Optical: LEDs are not visible at any angle. Optional white semi-gloss internal baffle reduces inline glare and striations on adjacent wall.

Standard Nomenclature Ship Eligible Driver **Mounting Method Paint Colors Paint Finish** Output ZTV10 0-10V Dim to 10% S Standard Output C Cable **BK** Black H High Gloss H High Output ZTV1 0-10V Dim to 1% S Swivel Stem W White (See color chart SG Semi-Gloss For all options, C Custom Output SEQ CA Earthquake for other colors) Stems/Fittings (see addendum page) **CCM** Custom Color Match see next page SF Surface Ceiling For wood finishes, see Color Temp. (nom) Length Option Manufacturer addendum page Unless ordered otherwise, 27 2700K 50 5000K N Nominal Gammalux cable mount canopies are 30 3000K RGB* S Specific Series white semi-gloss and all other **35** 3500K **RGBW** painted mounting components Beam match the fixture finish. 40 4000K Cross Section (nom) 2"x 5' UNIV - ZTV10 -C24" GB25WW ASYSL358 4'N OP WSG CRI** Suspension Length Options 8 for 80+ BPE Battery Pack (4' section) Distance to top of fixture. 9 for 90+ If not suspended, leave blank **DL** UL Damp Label Distribution **EMERG** Emergency Ckt Run or Pattern Wall Wash Shielding **2CKT** Dual Circuiting Specify total run length (i.e. 43' 5 1/8") Lamp Voltage DC Dust Cover, Clear 120V, 277V, For illuminated patterns, follow overall length with LED EBBWSG End Blade Baffle (2' each end), UNIV L, T, X, U, RECT or SQ. Examples: White Semi-Gloss 23'6" x 17'2" L Pattern would be 41'LPTTN. FBBWSG Full-length Blade Baffle, White 12' x 12' Square Pattern would be 48'SQPTTN. Semi-Gloss Lamp Configuration Provide leg dimensions as a line note in the spec. **OP** Open **ASY** Asymmetric

^{** 90+} CRI increases watts nom. 14.5%. # Sensor by Others (consult factory).







Specifications (continued on next page)

Electrical

Output: Standard (S) and high (H) options deliver a pre-set lumen package (see chart below). Custom-programmed output (C) is specified as LPF, WPF or % of High Output (see Custom Programmed Output page).

Static Driver: eldoLED Optotronic* programmable driver, wired for static operation (DVR).

0-10V Dimming: eldoLED Optotronic* programmable driver, wired for 0-10v control and dimming to 10% (ZTV10) or to 1% (ZTV1).

Step Dimming: Generic step dimming driver, two hot inputs for 100% and 50% output (SD2).

DALI Dimming: Generic DALI driver with two loose control wires exiting fixture at power feed location (DALI).

Lutron Dimming: Hi-Lume dim to 1% EcoSystem with Soft-On, Fade-to-Black (LDE1).

White Emitter: Nichia 757G emitters* binned within 3 MacAdam ellipses in Osram or Gammalux proprietary array. 90+ CRI option with extended lead time (CRI code 9) results in nominal 14.5% drop in efficacy; increase calculated watts 14.5%.

Battery Pack: Bodine BSL10T3* (BPE). 4W max input, 10W initial output, delivers min. 27% of High Output value per 4' length.

LED System: 70% lumen output (L70) at max 85 degrees C calculated at >60k hours. Fixtures are shipped with anti-static gloves to minimize the risk of damage to LEDs during installation. 5 year limited warranty.

Sensors: Sensors are as specified, confirmed by Gammalux prior to factory quote. Examples are Enlighted Micro Sensor, Lutron Athena Wireles Node, Lutron Vive, Wattstopper FS-205.

Upgrade Capability: LED assemblies can be replaced in the future with the latest factory-provided and fully warranted components. On-board sensors, control interface devices and alternate LED components may be specified (consult factory). Fixtures bear UL & cUL Dry Location label. Damp Location label available (**DL**).

*Subject to availability; may be substituted by Gammalux. Components and specifications may be changed without notice.

	STANI	DARD OUT	PUT LED		HIGH OUTPUT LED						
OPEN APERT	URE (OP)	DELIVERS	OPEN APERTURE (OP)			DELIVERS: 485.8 LPF					
ССТ	2700 K	3000 K	3500 K*	4000 K	5000 K	ССТ	2700 K	3000 K	3500 K*	4000 K	5000 K
WATTS / FT.	6.3	5.9	5.8	5.7	5.4	WATTS / FT.	8.6	8.2	8	7.8	7.4

Construction

Housing: BABA, ARRA, RoHS, REACH and Prop 65 compliant. Extruded aluminum body 2.00" wide x 5.00" high, 6063T5, 0.070" min thickness. Each housing is 12' max unless longer housings are pre-coordinated with the factory to reduce joints and installation labor. Fixtures are built per approved factory drawings and tested as a complete system at the factory. Continuous runs and patterns are ordered, built and shipped with a single item #. Fixtures ordered as individuals are not designed to be joined together in the field.

Joiner System: Automatic alignment, no loose parts, one tool to tighten factory installed bolts for hairline seam.

Lamping: Patterns are fully illuminated. Runs ordered in Specific Length (Length Option **S**) will be built to the exact dimension shown on signature-approved shop drawings. Runs ordered in Nominal Length (Option **N**) may be factory-adjusted to accomodate standard mounting positions or grid centers. Factory drawings will show all dimensions of mounting and power feed locations. Fixtures built to less than 4' may require remote driver installation - consult factory.

Mounting: Aircraft cable is 7x7 stranded stainless steel with stopper fitting at the top end. Lower end strands are welded and ground for easy insertion into adjustable cable gripper (**C**). Feed cord is straight, white 3/C SVT or SJT #18 AWG. Unless specified otherwise, cable mount canopies are white semi-gloss and all other painted mounting components match the fixture finish. Stems are 3/8" schedule 40 pipe with top swivels (**S**). California UBC compliant stems with internal safety cables available (**SEQ**). Housing can be mounted direct to wall (**WM**). Direct to surface mounting available (**SF**). Gammalux recommends mounting no less than 18" from the object wall.







Wall Wash - Suspended, Surface or Wall Mount Asymmetric Direct Distribution

Specifications (continued)

Optical

Reflector: Shall be asymmetric extruded aluminum painted high reflectance white.

Dust Cover: Clear acrylic dust cover, snap-in fitting (DC). Multiply delivered lumens by .97.

Internal Baffle: Optional, field removable baffle shall be formed steel, painted white semi-gloss (EBBWSG or FBBWSG). Multiply delivered lumens by .90.

Finish

Acid etched or clear annodized housing electrostatically sprayed with high solids aliphatic two component polyurethane high (H) or semi-gloss (SG) to an avg. thickness of 2 mils. Unless specified otherwise, cable mount canopies are white semi-gloss and all other painted mounting components match the fixture finish. Custom finish, consult factory. Wood Finishes, back page.



Packing and Shipping

Fixtures built for continuous rows and patterns are given a specific location identifier, clearly identified on factory layout drawings, the fixture's ID Label, protective wrapping and on each end of fixture carton. Shipping pallets are built with 2" clearance, extending beyond the length and width of cartons, providing shipping protection.

Approx. weight of 4' module is 16 lbs. including carton. Weight of pallet and supplemental packing materials not factored in.

Internal Blade Baffle

Fixtures built with no internal baffle (**OP** or **DC**) may create lateral glare for viewers in a corridor and striations on adjacent walls in a wall-to-wall installation.

Internal 2' end baffle (EBBWSG) provides lateral cu







Photometric Reports for STANDARD OUTPUT FIXTURES

FIXTURE USES OPEN APERTURE AND 3500 K BOARDS. @ 80+ CRI

IESNA: LM 79-2008 ISSUEDATE: 1/31/2017

TEST: GB25WW1SL358-4.IES
TESTLAB: PLI ENTERPRISES INC

MANUFAC: GAMMALUX LIGHTING SYSTEMS

LUMCAT: GB25WW-1SL358-OP LAMPS: PLPG2-BAR-1100-835-289X38-DC


EFFICACY (Total): 61.8 LPW
DISTRIBUTION % UP: 3.8%
DISTRIBUTION % DOWN: 96.2%
CIE CLASSIFICATION: DIRECT


LUMINOUS OPENING: RECTANGULAR

Width: 4.00 (Feet)

Length: 0.17 Height: 0.50


INPUT WATTS: 0.50













Photometric Reports for HIGH OUTPUT FIXTURES

FIXTURE USES OPEN APERTURE AND 3500 K BOARDS. @ 80+ CRI

IESNA: LM 79-2008 ISSUEDATE: 1/31/2017

TEST: GB25WW1HL358-4.IES
TESTLAB: PLI INTERPRISES INC

MANUFAC: GAMMALUX LIGHTING SYSTEMS
LUMCAT: GB25WW-1HL358-120V-DVR-4'N-OP

LAMPS: 96 WHITE LEDS

EFFICACY (Total): 61.7 LPW
DISTRIBUTION % UP: 3.8%
DISTRIBUTION % DOWN: 96.2%
CIE CLASSIFICATION: DIRECT

LUMINOUS OPENING: RECTANGULAR


Width: 4.00 (Feet)

Length: 0.17 Height: 0.50

INPUT WATTS: 31.2















Mounting Details

Factory Drawings: Fully dimensioned factory drawings will be provided upon receipt of purchase order.


Cable Mount: Specify C code in catalog



Swivel Stem Mount: Specify S code in catalog




CA Earthquake Stem Mount: Specify SEQ code in catalog



Surface Mount:

Specify SF code in catalog #



Gammalux Lighting Systems reserves the right to change the details of fixture design and construction at any time.







Custom Programmed Output

Custom Programmed Output can be specified to produce approximate Delivered Lumens per Foot, Percentage of High Output Value or Maximum Watts per Foot.

Delivered Lumens Per Foot

Gammalux deals only in delivered lumens per foot. When working to match or exceed a competitor product's Lumens Per Foot package, be sure you are looking at their Delivered (through the lens) lumens per foot, not their System (bare board) lumens per foot.

In the Gammalux item #, use C as the Output designator and add a fixture description stating the required Lumens Per Foot value (ie: if you need 600 lumens per foot delivered by the fixture, the line note would read "Program = 600 LPF").

Percentage of High Output Value

If the required delivered lumens per foot are not known, run lighting calculations using our High Output IES file and identify the percentage of increase or decrease required to produce the correct lighting in the space.

In the Gammalux item #, use C as the Output designator and add a fixture description stating the required percentage of decrease from our High Output value (ie: for 60% of our High Output value, the line note would read "Program = 60% of High Output").

Maximum Watts Per Foot

In the Gammalux item #, use C as the Output designator and add a fixture description stating the required Maximum Watts per Foot (ie: if you need the fixtures capped at a maximum of 7 watts per foot, the line note would read "Program = 7 WPF").

For all three methods, custom programming capability is currently 25-200% of our High Output value. For requirements outside of this range, consult factory.





Application Guide


The images on this page depict several typical installations and the resulting light levels as calculated in a computer model scenario.

Examples are of a 16' installation centered on a 24' wall. Reflectivity assumptions are: ceiling 80%, walls 50%, floor 20%. The values represented are the footcandle levels obtained in the horizontal center of the wall. The fixture is using High Output LED boards with 3500K diodes.

Although the LED boards are hidden from view, the inside of the fixture is bright. This will be visible to room occupants positioned between the fixture and the wall.

Example:

• In a 7' ceiling with the fixture mounted 36" from the wall, the user obtains an average of 44fc with a max of 49 and a min of 42



Example:

• In a 9' ceiling with the fixture mounted 30" from the wall, the user obtains an average of 40fc with a max of 55 and a min of 26.



Examples:

• In a 11' ceiling with the fixture mounted 24" from the wall, the user obtains an average of 35fc with a max of 67 and a min of 14.









Application Guide

The images on this page depict several typical installations and the resulting light levels as calculated in a computer model scenario.

Examples are of a 16' installation centered on a 24' wall. Reflectivity assumptions are: ceiling 80%, walls 50%, floor 20%. The values represented are the footcandle levels obtained in the horizontal center of the wall. The fixture is using High Output LED boards with 3500K diodes.

Although the LED boards are hidden from view, the inside of the fixture is bright. This will be visible to room occupants positioned between the fixture and the wall.

Example:

• In a 9' ceiling with the fixture mounted 30" from the wall, the user obtains an average of 44fc with a max of 60 and a min of 32. Fixtures are suspended 6" from the ceiling.



Examples:

• In a 11' ceiling with the fixture mounted 24" from the wall, the user obtains an average of 35fc with a max of 71 and a min of 21. Fixtures are suspended 12" from the ceiling.









Wood Finishes

Fixture housings are powder coated with a base finish, baked, then wrapped in a film with the decorative grain pattern. Baking the housing again allows the grain to become embedded into the powder coated finish. This is not a decal or veneer. Additional lead time and cost increases apply. Consult factory for pricing. Swatches are 3" x 4".









FINISH CODE: MED





FINISH CODE: WAL

FINISH CODE: AOK

FINISH CODE: FWG






FINISH CODE: MH2

DUE TO VARIANCES IN MONITORS AND PRINTERS, ACTUAL FINISHES MAY APPEAR DIFFERENT FROM SWATCHES.









Approved Cut Release option

If offered for Approved Cut Release in the Gammalux factory quote, the product in the accompanying purchase order is authorized by the GC to be released to production without the need for factory drawings for approval.

I confirm that:

- all ordering options are clearly noted (highlighted, boxed, written in, etc.) on page 1 of this
 fixture cut sheet
- quoted leadtime begins upon Gammalux's confirmation that the P.O. and marked cut sheet match their quote.
- the order will be released to production and a "record only" drawing will be provided prior to product shipment
- changes after Gammalux's release to production will result in a minimum 25% change fee which increases as production progresses.

General Contractor	
GC's authorized Signature (or stamp below)	
(
Signatory's printed name	

